



PROJECT	REF	REV	ITEM CODE	\bigcirc
LOCATION	DATE		PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Welson (PRC) Chrome plated brass angle stop valve for fresh water	Illustration/ Drawing
Dimensions	Refer to drawing	
Model	2728	
Finish	Brass/ Chrome Plated	
Manufacturer	Welson (PRC)	
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
Working Pressure : 0.5 ~ 10 b Test Pressure : 20 bar Comply with : BS1010 Approval Reference : Acceptance Reference No. ;	Male Plated Brass ar Office of Hong Kong Water Supplies Department (2) in WSD 3321/16 Pt.1 T/J(317) C20160395 15 January 2021 00 DCB3 00 DCB3 per	$\begin{array}{c} & 52 \\ \hline \\ $

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



本署檔號 Our ref. 來函檔號 Your ref.

: (2) in WSD 3321/2021 T/J(110/2021)

電話 Tel. 傳真 : 2824 0578 Fax.

26 February 2021

Approval of "WELSON" Angle Valve (General Acceptance No. C20210167)

Your letter ref. WEL-2728-12292020AP dated 29 December 2020 refers.

Having considered the test report ref. 204659PC200249 issued on 28 December 2020 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Welson Metal & Sanitary Ware MFY		
Country of Origin:	the Mainland of China		
Brand:	Welson		
Details of Fitting:	1/2" Copper alloy angle valve		
Model:	2728		
Body Markings:	WELSON 2728		
Expiry Date:	7 December 2025		



This Authority hereby permits the use of the above fitting in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG) for Director of Water Supplies

Encl.

c.c.

WSD 3321/1/82] - without catalogue ME/MC] - with soft copy only

General Acceptance No. C20210167