



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

### SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Delabie (France) Binoptic wall concealed chrome plate spout for partition wall or panel, 230V AC supply ; nominated flow rate <b>3.4 L/min</b> in WELS <b>Grade 2</b> ; Registration No. TN 19-0052	<p>Illustration/ Drawing</p>
Model	379DER	
Finish	Chrome Plated	
Manufacturer	Delabie (France)	
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
<p>Recessed electronic basin mixer: Independent IP65 electronic control unit. 230/12V mains supply with transformer. Flow rate pre-set at 3 lpm at 3 bar, can be adjusted from 1.5 to 6 lpm. Scale-resistant flow straightener. Adjustable duty flush (pre-set flush ~60 sec. every 24hr after last use). Active, infrared presence detection, sensor at the end of the spout optimises detection. Filters and solenoid valves M3/8". Chrome-plated brass body. Chrome-plated spout L.205mm for cross wall installation ≤ 190 mm. Cable for sensor, flexibles and mounting all pass through the same hole. Anti-blocking safety. Spout with smooth interior and low volume of water (reduces niches where bacteria can develop).</p>		<p><b>ADVANTAGES</b></p> <ul style="list-style-type: none"> <li>Independent IP65 electronic control unit</li> <li>Water savings up to 90%</li> <li>Total hygiene: no manual contact</li> <li>Anti-bacterial proliferation duty flush</li> </ul>
Connector	M3/8"	
Technology	Electronic	
Spout length	205mm	
Flow rate	3 lpm	
Standards and certifications		

Note:

\* All information of the above is for reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.):

TN 19-0052



自願參與用水效益標籤計劃 - 水龍頭  
Voluntary Water Efficiency Labelling Scheme - Water Taps



茲證明

This is to certify that

將下列水龍頭在本計劃內註冊：  
has registered the following water tap under this scheme :

牌 子 / Brand	:	Delabie
型 號 / Model	:	379DER
種 類 / Type	:	Non-mixing
原產地 / Country or Region Origin	:	France

在用水效益標籤上展示的標誌

*Symbolic Presentation on the Water Efficiency Label* :



滴水點

*Water droplet(s)*

用水效益級別

*Water Efficiency Grade* :

2

with additional merit\*

耗水量

*Water Consumption* :

3.4

公升/分鐘

*litres/minute*

\*with additional merit of "Automatic closing mechanism"

簽發日期：

Date of Issue:

12 April 2019



水務署

Water Supplies Department



水務署署長(張業駒代行)  
for Director of Water Supplies



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署  
Our  
來函  
Your ref.



321/2022 T/J(530/2022)

電話

Tel.

傳真

Fax.

2824 0578

27 September 2022



**Approval of “DELABIE” Sensor Tap  
(General Acceptance No. C20220911)**

Your letter ref. 379DER dated 4 May 2022 and subsequent submissions received by this department up to 30 August 2022 refer.

Having considered the test report ref. J25227Ar3 issued on 4 July 2022 by Nutek Systems (HK) Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Delabie SCS

**Country of Origin:** France

**Brand:** Delabie

**Details of Fitting:** 3/8" Wall mounted sensor tap with 1 no. of flexible hose approved by UK's WRAS under ref. 1811040

**Model:** 379DER

**Body Markings:** **DELABIE**

**Expiry Date:** 30 November 2023



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only