



水務署
Water Supplies Department

總部 Headquarters

告士打道七號入境事務大樓 48 樓
7 Gloucester Road, Gloucester Tower, 7 Gloucester Road, Wan Chai, Hong Kong



本署檔號
Our ref.
來函檔號
Your ref.

21/2023 T/J(397/2023)

電話 :
Tel. :
傳真 : 2824 0578
Fax. :

13 June 2023



**Approval of “MCM” Self Closing Tap
(General Acceptance No. C20230408)**

Your letters dated 21 April 2023 and 16 May 2023 refer.

Having considered the test report ref. RBBB012r1 issued on 12 May 2023 by Ideal Test Consultants Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Rubinetterie MCM Intl Srl
Country of Origin: Italy
Brand: MCM
Details of Fitting: 1/2" Self closing basin tap
Model: 9001A
Body Markings: MCM
MADE IN ITALY
Expiry Date: 27 December 2027



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Catlin Kit Wai, Stephen)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only