



Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong

Tel: 2388 7171 Fax: 2710 8012

Email: acme@acmesanitary.com.hk

Website: www.acmesanitary.com.hk



For Precious Life

PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Inax (Japan) Chrome plated self closing faucet with large push button; Nominal flow rate 1.6L/min in WELS Grade 1; Registration No. TN 18-0070	<div>Illustration/ Drawing</div>
Dimensions	L136 x W54 x H137 mm	
Model	LFV-P02B	
Finish	Chrome Plated	
Brand/ Production Origin	Inax (Japan)/ Vietnam	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	

Dynamic flow pressure (kPa)	50	150	250	350	500
Flow rate (l/min)	1.45	1.50	1.65	1.70	1.70

Note:



* All information of the above is for the reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.) :

TN 18-0070



自願參與用水效益標籤計劃 - 水龍頭
Voluntary Water Efficiency Labelling Scheme - Water Taps



茲證明
This is to certify that

將下列水龍頭在本計劃內註冊：
has registered the following water tap under this scheme :

牌子 / Brand	:	INAX
型號 / Model	:	LFV-P02B + A5.9042.1
種類 / Type	:	Non-mixing
原產地 / Country or Region Origin	:	Vietnam

在用水效益標籤上展示的標誌

Symbolic Presentation on the Water Efficiency Label



滴水點

Water droplet(s)

用水效益級別

Water Efficiency Grade

1

with additional merit*

耗水量

Water Consumption

1.6

公升/分鐘

litres/minute

*with additional merit of "Automatic closing mechanism"

簽發日期：
Date of Issue:

31 October 2018



水務署
Water Supplies Department



水務署署長(黃恩諾代行)
for Director of Water Supplies



水務署
Water Supplies Department

總部 Headquarters



打道七號入境事務大樓 48 樓

Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號
Our ref.
來函檔號
Your ref.

21/2023 T/J(1056/2023)

電話 :
Tel. :
傳真 : 2824 0578
Fax. :

13 November 2023



**Approval of “INAX” Self Closing Tap
(General Acceptance No. C20230838)**

Your E-Application [file-id: ETJ-GA-20231013-145] dated 24 October 2023 refers.

Having considered the test report ref. 221004PC230045 issued on 7 October 2023 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Branch of Lixil Vietnam Corporation in Quang Nam

Country of Origin: Vietnam

Brand: INAX

Details of Fitting: 1/2" Deck mounted self closing tap

Model: LFV-P02B

Body Markings: **INAX**

Expiry Date: 24 April 2028



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only