

PROJECT	REF	REV	ITEM CODE	
LOCATION	DATE		PAGE	

SANITARY WARE SPECIFICATION SHEET Item Descriptions Welson (PRC) Stainless Steel Grade 316 Illustration/ Drawing Angle Stop Valve with Plastic Piston (1/2" Female threaded) for Sea Water with 12" plastic riser pipe Model 2738 + BC12-1/2Material Grade 316 (Angle valve) Plastic (Riser pipe) ACME SAMITARY WARE Manufacturer Welson (PRC) Supplier Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen Contact Tel/Fax (852) 2388-7171 / (852) 2710-8012 E-mail acme@acmesanitary.com.hk Website www.acmesanitary.com.hk Specifications Model No. : 2738 : 1/2" BSP Female Inlet : 3/8" BSP Male Outlet O Ring : Stainless Steel grade 316 Construction Working Pressure: 0.5 ~ 10 bar Piston-Test Pressure : 20 bar Gasket 64 Comply with : BS1010 Approval : Office of Hong Kong Water Supplies Department Approval : (2) in WSD 3321/16 Pt.1 T/J(413) Reference Acceptance Reference No.: C20160357 : 15 January 2021 Expiry Date Material Construction Description / Material / Stainless Steel grade 316 Body 30.5 Piston / Plastic Polyamide O Ring / H.G.S.N. Rubber Gasket / H.G.S.N. Rubber

Note:

^{*} All information of the above is for the reference only. No prior notice is made if any changes.



48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號

: (2) in WSD 3321/2021 T/J(107/2021) Our ref.

Tel.

來函檔號 Your ref.

傅真 Fax.

: 2824 0578

26 February 2021

Approval of "WELSON" Angle Valve (General Acceptance No. C20210164)

Your letter ref. WEL-2738-12292020AP dated 29 December 2020 refers.

Having considered the test report ref. 204659PC200249(4) issued on 28 December 2020 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

Welson Metal & Sanitary Ware MFY

Country of Origin:

the Mainland of China

Brand:

Welson

Details of Fitting:

1/2" Stainless steel angle valve

Model:

2738

Body Markings:

WELSON 2738 316

Expiry Date:

7 December 2025





This Authority hereby permits the use of the above fitting in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue ME/MC] - with soft copy only