

Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong Tel: 2388 7171 Fax: 2710 8012 Email: acme@acmesanitarv.com.hk Since 1949 Website: www.acmesanitary.com.hk



PROJECT	REF	REV	ITEM CODE	
LOCATION	DATE		PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions GROHE (Germany) "Euroeco Special" Chrome plated wall mounted basin mixer 1/2"; nominated flow rate 5 L/min in WELS Grade 1; Registration No. TM 21-0297

L257 x W150 x H196 mm Dimensions

Model 32773000

Finish Chrome Plated

Manufacturer **GROHE Limited**

Country of Origin Germany

Supplier Acme Sanitary Ware Co. Ltd

Mr. Eric Wong/ Mr. Don Yuen


Contact Tel/Fax (852) 2388-7171 / (852) 2710-8012

E-mail acme@acmesanitary.com.hk Website www.acmesanitary.com.hk

"Euroeco Special" Basin mixer 1/2"

Product Descriptions

- wall mounted
- GROHE StarLight chrome finish
- GROHE SilkMove 46 mm ceramic cartridge
- · GROHE EcoJoy technology for less water and perfect flow
- · adjustable flow rate limiter
- adjustable temperature limiter
- adjustable minimum flow rate 2.5 l/min
- cast swivel spout, lockable
- laminar flow straightener 9 l/min
- projection 257 mm
- metal lever
- lever length 170 mm
- S-unions





^{*} All information of the above is for the reference only. No prior notice is made if any changes.

TM 21-0297



自願參與用水效益標籤計劃-水龍頭 Voluntary Water Efficiency Labelling Scheme - Water Taps



This is to certify that

將下列水龍頭在本計劃內註冊: has registered the following water tap under this scheme:

Grohe / Brand

32773XXX + 403655031 / Model

Mixing / Type

Germany / Country or Region Origin 原產地

(Mixer & Flow Controller)

XXX - denotes the code of colour

在用水效益標籤上展示的標誌

滴水點 Symbolic Presentation on the Water Efficiency Label Water droplet(s)

用水效益級別

1 Water Efficiency Grade

耗水量 公升/分鐘 5.0 Water Consumption litres/minute

26 November 2021 簽發日期: Date of Issue:





水務署署長(尤孝賢代行) for Director of Water Supplies



本署檔號 Our ref. 來函檔號

Your ref.

(2) in WSD 3321/2021 T/J(963/2021)

電話

Tel.

傅真 Fax.

: 2824 0578

23 July 2021



Approval of "GROHE" Basin Mixer (General Acceptance No. C20210797)

Your letter ref. WRC/2576 dated 18 June 2021 refers.

Having considered the test report ref. J26494A issued on 31 May 2021 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

Grohe AG

Country of Origin:

Germany

Brand:

Grohe

Details of Fitting:

1/2" Single lever basin mixer

Model:

32773XXX

(where "XXX" denote the code of colour)

Body Markings:

GROHE

Expiry Date:

2 May 2026





This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue ME/MC] - with soft copy only