









Acme Sanitary Ware Co Ltd

Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong
 Tel: 2388 7171 Fax: 2710 8012
 E-mail: acme@acmesanitary.com.hk
 Website: www.acmesanitaryware.com.hk



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	GROHE (Germany) "Minta" Chrome plated single lever sink mixer;Nominal flow rate 5.1L/Min in WELS Grade 2 ; Registration No. TM 18-0049					Illustration/ Drawing												
Dimensions	L223 x W140 x H356					 <div></div>												
Model	32917000 + 64647040																	
Finish	Chrome Plated																	
Country of Origin	Portugal																	
Manufacturer	GROHE Limited																	
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen																	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012																	
E-mail	acme@acmesanitary.com.hk																	
Website	www.acmesanitary.com.hk																	
<table><tr><td>Dynamic flow pressure (kPa)</td><td>50</td><td>150</td><td>250</td><td>350</td><td>500</td></tr><tr><td>Flow rate (l / min)</td><td>2.68</td><td>4.48</td><td>5.40</td><td>5.38</td><td>5.70</td></tr></table> <p>Minta Single-lever sink mixer 1/2" C-spout single hole installation GROHE StarLight finish GROHE SilkMove 46 mm ceramic cartridge adjustable flow rate limiter swivel tubular spout selectable swivel area: 0° / 150° / 360° flexible connection hoses connector set 3/8" rapid installation system optional temperature limiter ref. no. 46 308</p> 							Dynamic flow pressure (kPa)	50	150	250	350	500	Flow rate (l / min)	2.68	4.48	5.40	5.38	5.70
Dynamic flow pressure (kPa)	50	150	250	350	500													
Flow rate (l / min)	2.68	4.48	5.40	5.38	5.70													

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.): TM 18-0049



自願參與用水效益標籤計劃 - 水龍頭

Voluntary Water Efficiency Labelling Scheme - Water Taps



茲證明

This is to certify that

將下列水龍頭在本計劃內註冊：

has registered the following water tap under this scheme :

牌子 / Brand	:	GROHE
型號 / Model	:	32917000 + 64647040
種類 / Type	:	Mixing
原產地 / Country or Region Origin	:	Portugal

在用水效益標籤上展示的標誌

Symbolic Presentation on the Water Efficiency Label :



滴水點

Water droplet(s)

用水效益級別

Water Efficiency Grade

:

2

耗水量

Water Consumption

:

5.1

公升/分鐘

litres/minute

簽發日期：
Date of Issue:

15 February 2018



水務署

Water Supplies Department



水務署署長(周世威代行)
for Director of Water Supplies



水務署
Water Supplies Department

總部
香港
48



事務大樓 48 樓
48 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3521/19 Pt.1 T/J(181)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 July 2019

**Approval of "GROHE" Sink Mixer
(General Acceptance No. C20190368)**

Your letter ref. WRC/2039 dated 13 February 2019 and subsequent submission received by this department on 21 June 2019 refer.

Having considered the test report ref. J23823Ar1 issued on 3 June 2019 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG

Country of Origin: Portugal

Brand: Grohe

Details of Fitting: 3/8" Single lever sink mixer

Model: 32917XXX
(where the digits "XXX" denote the code of colour)

Body Markings:

Expiry Date: 1 January 2024



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only