



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

## SANITARY WARE SPECIFICATION SHEET

Item Descriptions	GROHE (Thailand) "Eurostyle" Single-lever basin mixer 1/2" S-Size; nominated flow rate <b>4.9 L/min</b> in WELS <b>Grade 1</b> ; Registration No. TM 22-0118	Illustration/ Drawing
Dimensions	L110 x W50 x H210 mm	
Model	33558LS3	
Finish	Moon White	
Country of origin	Thailand	
Manufacturer	GROHE Limited	
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
<p><b>"Eurostyle"</b> <b><u>Basin mixer 1/2" S-Size</u></b></p> <ul style="list-style-type: none"><li>• monobloc installation</li><li>• loop metal lever</li><li>• <b>GROHE SilkMove</b> 35 mm ceramic cartridge</li><li>• adjustable flow rate limiter</li><li>• with temperature limiter</li><li>• <b>GROHE StarLight</b> finish</li><li>• <b>GROHE EcoJoy</b> mousseur 5.7 l/min</li><li>• <b>GROHE FastFixation</b> rapid installation system</li><li>• pop-up waste set 1 1/4"</li><li>• flexible connection hoses</li></ul>		
<p><b>Colour options:</b> ● 003 Chrome    ○ LS3 MoonWhite</p> <div></div> <p>33558003      33558LS3</p>		

\* All information of the above is for the reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.): TM-22-0118



自願參與用水效益標籤計劃 - 水龍頭  
Voluntary Water Efficiency Labelling Scheme - Water Taps




茲證明  
This is to certify that

將下列水龍頭在本計劃內註冊：  
has registered the following water tap under this scheme :

牌子 / Brand	:	Grohe
型號 / Model	:	33558XX3 + 402717040
種類 / Type	:	Mixing
原產地 / Country or Region Origin	:	Thailand (Mixer) Germany (Flow Controller)

XX – denotes the code of colour

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:		滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1	
耗水量 <i>Water Consumption</i>	:	4.9	公升/分鐘 <i>litres/minute</i>

簽發日期: 10 June 2022  
Date of Issue:



水務署  
Water Supplies Department



水務署署長(林麗恒代行)  
for Director of Water Supplies



水務署  
Water Supplies Department

總部 Headquarters

告士打道七號入境事務大樓 48 樓

ation Tower, 7 Gloucester Road, Wan Chai, Hong Kong



本署  
Our ref.  
來函編號  
Your ref.

3321/2021 T/J(1302/2021)

電話  
Tel.  
傳真  
Fax.

:  
:  
: 2824 0578

12 October 2021



**Approval of "GROHE" Basin Mixer  
(General Acceptance No. C20211112)**

Your letter ref. WRC/2616 dated 23 August 2021 refers.

Having considered the test report ref. J26793A issued on 24 July 2021 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Grohe AG  
**Country of Origin:** Thailand  
**Brand:** Grohe  
**Details of Fitting:** 3/8" Single lever basin mixer  
**Model:** 33558XX3  
(where "XX" denote the code of colour)  
**Body Markings:**   
**Expiry Date:** 4 July 2026



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only