




Acme Sanitary Ware Co Ltd

Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong
 Tel: 2388 7171 Fax: 2710 8012
 E-mail: acme@acmesanitary.com.hk
 Website: www.acmesanitaryware.com.hk



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	GROHE (Germany) Chrome plated Europlus E infra-red electronic basin mixer 1/2" in AC supply ; Nominal flow rate 4.2L/Min in WELS Grade 1 ; Registration No. Tm17-0113	Illustration/ Drawing
Dimensions	L154 x W52 x H149 mm	
Model	36015001	
Material	Chrome Plated	
Manufacturer	GROHE Limited	
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Wilson Hung	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
<div>Europlus E<ul style="list-style-type: none">• Single hole installation• Quick installation system• 7 pre-set programs:• 24/72 hours autoflush• Time or user dependent• Cleaning mode• Safety stop after 60 sec.• Additional functions by remote control:• Adjustable flow time• Adjustable reflection range by remote• Activation of thermal disinfection for 3.5 or 11 min by hand• GROHE EcoJoy® Mousseur 1.5 gpm• Solenoid valve• 2 Flexible hose connections• Non-return valve• Dirt strainers• CE approved<ul style="list-style-type: none">type of protection faucet IP 59Ktype of protection plug transformer IP 44• Noise classification 1 in accordance with DIN4109 incl. certificate• GROHE EcoJoy® technology for less water and perfect flow• GROHE StarLight® finish</div>		

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



自願參與用水效益標籤計劃 - 水龍頭
Voluntary Water Efficiency Labelling Scheme - Water Taps

Certificate of 註冊證書
Registration

茲證明

This is to certify that

Grohe Hong Kong Limited

將下列水龍頭在本計劃內註冊：
has registered the following water tap under this scheme:

牌 子 / Brand	:	GROHE
型 號 / Model	:	36015001
種 類 / Type	:	Mixing
原產地 / Country or Region Origin	:	Germany

在用水效益標籤上展示的標誌

Symbolic Presentation on the Water Efficiency Label :



滴水點

Water droplet(s)

用水效益級別

Water Efficiency Grade :

1

with additional merit*

耗水量

Water Consumption :

4.2

公升/分鐘

litres/minute

*with additional merit of "Automatic closing mechanism"

簽發日期：
Date of Issue:

11 August 2017



水 務 署

Water Supplies Department



水務署署長(周世威代行)
for Director of Water Supplies



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(1724)

23 March 2017



Approval of "GROHE" Basin Mixer

Your letter ref. WRC/1273 dated 20 December 2016 and subsequent submission received by this department on 13 March 2017 refer.

Having considered the test reports ref. J20252 and J21179r1 issued on 6 December 2016 and 3 March 2017 respectively by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG

Country of Origin: Germany

Brand: Grohe

Details of Fitting: 3/8" Infra-red electronic basin mixer supplied with one pair of stainless steel wire braided water inlet flexible hose (manufactured by Neoperl GmbH. Model: Neoflex SPX DN6 G3/8") approved by UK's WRAS under ref. 1506306

Model: 36015001

Body Markings:



Expiry Date:

16 November 2021 (for mixer)
30 June 2020 (for hose)

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,

A handwritten signature in black ink, appearing to read "Chan Chung Kun".

(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only