PROJECT	REF	REV	ITEM CODE	
LOCATION	DATE		PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Delabie (France) "Tempostop" Chrome plated brass lever operated automatic shutoff basin tap, shut-off time delay 7 sec., with conical inlet M ½"
Model	745440
Finish	Chrome Plated
Manufacturer	Delabie (France)
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen
Contact Tel/Fax E-mail	(852) 2388-7171 / (852) 2710-8012 acme@acmesanitary.com.hk
Website	www.acmesanitary.com.hk

DESCRIPTION

TEMPOSTOP - Ref. 745440

Deck-mounted time flow lever-operated basin tap:

Time flow ~7 sec.

Flow rate pre-set at 3 lpm at 3 bar, can be adjusted from 1.5 to 6 lpm.

Tamperproof scale-resistant flow straightener.

Solid chrome-plated brass body M1/2".


Fixing reinforced by back-nut.


>Lever control (soft-touch operation).

TECHNICAL FEATURES

TEMPOSTOP - Ref. 745440

Connector	M1/2"
Technology	Time flow
Drop height	35mm
Spout length	110mm
Flow rate	3 lpm
Standards and certifications	







46/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 Our ref. 來函檔號

Your ref.

(4) in WSD 3321/2021 T/J(509/2021)

電話

Tel.

尊真

: 2824 0578

20 May 2021

Approval of "DELABIE" Self Closing Tap (General Acceptance No. C20210534)

Your letters both ref. 745440 dated 24 March 2021 and 29 April 2021 refer.

Having considered the test report ref. J25744r1 issued on 20 April 2021 by Nutek System (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

Delabie SCS

Country of Origin:

France

Brand:

Delabie

Details of Fitting:

1/2" Self closing basin tap

Model:

745440

Body Markings:

DELABIE

Expiry Date:

1 December 2025





This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue ME/MC] - with soft copy only