



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			LEGEND	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Siamp (Vietnam) "HANDY" 1/2" extractable and extendable bottom inlet valve fitting	<p>Illustration/ Drawing</p>
Dimensions	Refer to drawing	
Model	90T EVO	
Material	Plastic	
Manufacturer	Siamp	
Country of Origin	Vietnam	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
<p>Product Descriptions</p> <ul style="list-style-type: none"> • Specific for dirty water • To be installed into ceramic or plastic, cisterns, for replacement or as original equipment • Mechanical closure • Adjustable water level • Height 287MM, (brass or plastic) • Flow rate: 0.15 l/s at 3 bars • Pressure function range: from 0.10 to 8 bars • Anti backflow option • Refill with reducer option 		

Note:

- 1) Extractable
- 2) Extendable
- 3) Torque requirement : 15N

Any excess the torque requirement may cause the damage.

* All information of the above is for the reference only. No prior notice is made if any changes.



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

7 Gloucester Road, Wan Chai, Hong Kong



本署檔號
Our ref.
來函檔號
Your ref.

1/2023 T/J(578/2023)

電話
Tel. :
傳真
Fax. : 2824 0578

12 September 2023



**Approval of "SIAMP" Float Operated Valve
(General Acceptance No. C20230673F)**

Your letter dated 24 May 2023 and subsequent submissions received by this department up to 17 August 2023 refer.

Having considered the test report ref. RSIA002 issued on 28 April 2023 by Ideal Test Consultants Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Siamp Ltd
Country of Origin: Vietnam
Brand: Siamp
Details of Fitting: 1/2" Plastic float operated valve
Model: 90T EVO
Body Markings: **SIAMP**
Expiry Date: 20 April 2028

Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The flushing volume of the flushing valve should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush."

"The fitting should be used within the range of working pressures specified by the manufacturer." AND

"The installed fitting should not result in backflow of water that will contaminate the flushing water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only