



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	SIAMP (Monaco brand) "OPTIMA" Plastic watercloset dual flush drop valve
Dimensions	Refer to drawing
Model	OPTIMA 49
Finish	Plastic
Manufacturer	SIAMP
Brand Origin	Vietnam
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Wilson Hung
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012
E-mail	acme@acmesanitary.com.hk
Website	www.acmesanitary.com.hk

Illustration/ Drawing

OPTIMA 49

Dual flush valve WRAS and NF certified, compact and water saving. The stirrup fixes the cistern lid once the button is screwed down and enables a non alignment position. Adjustable button with optional collar.

Adjustable height from 282 and 430 mm, lid hole from 16 to 50, discharge hole from 58 to 72 mm. Adjustable : small flush, over flow, dead water level.

- > Can be installed into plastic or ceramic cisterns
- > Push button: dual flush
- > Actuation effort below 20 Newton
- > For lid holes ranging from 16 to 50mm, with or without collar depending on the diameter
- > Button off-center +/- 15mm
- > Stirrup: adjustable in increments of 12 mm
- > Overflow can be cut in increments of 4mm
- > Adjustable small flush, from 2l to 4.5l
- > Adjustable deadwater level
- > High flush rate of 3.5l/s
- > Foam pan seal supplied for compensating pan irregularity

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

7 Gloucester Road, Immigration Tower, Wan Chai, Hong Kong

本署檔號
Our ref.
來函檔號
Your ref.



/2024 T/J(253/2024)

電話 :
Tel. :
傳真 : 2824 0578
Fax. :

21 June 2024

Dear Sir/Madam,

**Approval of “SIAMP” Flush Valve
(General Acceptance No. C20240382F)**

Your letter dated 21 March 2024 and subsequent submissions received by this department up to 31 May 2024 refer.

Having considered the test report ref. RSIA003 issued on 29 May 2024 by Ideal Test Consultants Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Siamp Ltd
Country of Origin: Vietnam
Brand: Siamp
Details of Fitting: 2" Plastic dual flush valve
Model: OPTIMA 49
Body Markings: **SIAMP**
Expiry Date: 11 March 2029



Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The flushing volume of the flushing valve should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush."

"The fitting should be used within the range of working pressures specified by the manufacturer." AND

"The installed fitting should not result in backflow of water that will contaminate the flushing water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only